



NATIONAL TRANSMISSION AND DESPATCH COMPANY LIMITED

Chief Engineer (Design & Standards) NTDCL

No. 4525-49/CEDS/Z-224 Dated 17/11/2016


Chief Executive Officer,
All DISCOs

Atten: Chief Engineer/ Manager (MM)

Subject: DISPLAY OF ITEMS IN NORMAL & ALT MODES IN BIDIRECTIONAL METERING (AMENDMENT NO. 6 IN WAPDA SPECIFICATION DDS-60:2007)

Ref: This office letter No.4400-4425/CEDS/z-244 dated 08.11.2016.

Enclosed herewith a coloured copy, showing style of the name plate to be used in 3-Phase Whole Current Static Energy Meter (BIDIRECTIONAL / NET METERING) is considered instead of already circulated vide this office letter referred above.


(ENGR. BASHIR AHMAD BHATTI) 17/11/16
CHIEF ENGINEER (D&S) NTDCL

D/A: As above

Cc to:-

1. General Manager (Technical) NTDCL, WAPDA House, Lahore.
2. General Manager (S.D) NTDCL, WAPDA House, Lahore.
3. General Manager (GSO) NTDCL, WAPDA House, Lahore.
4. General Manager (GSC) NTDCL, WAPDA House, Lahore.
5. Chief Engineer (Material Inspection) NTDCL, Sunny View, Lahore, for necessary action.
6. All meter manufacturers, for necessary action.

along with the above mentioned documents for information

along with the above mentioned documents for information & necessary action

K-B-K

NAME PLATE SAMPLE FOR 3-PHASE (BI-DIRECTIONAL) WHOLE CURRENT TOU ENERGY METER

BI-DIRECTIONAL/GREEN METERING



3-Phase Whole Current TOD/TOU

P.O. No.
Mfg. Year:
Sr. No:



3-Phase 4-Wire



imp/kWh imp/kvarh
Class 1.0 Class 2.0



DDS-60:2007
DDS-98:2011
3 x 230 / 400V
10 (100)A, 50Hz



Scroll

MDI
Reset



Important Display Sequence

- 06- kWh Import (Rate A)
- 07- kWh Export (Rate A)
- 08- kWh Import (Rate B)
- 09- kWh Export (Rate B)

Purchaser/DISCO