

Power Information Technology Company (PITC)
PITC Tender No. PITC/G-224(27)/02-2019

Sr. No.	Page No.	Clause No.	Description	Question	Clarification
1	-	3.3.6(i)	The bidder shall furnish, as part of its bid, a bid security as mentioned at Sr. No 6 of clause 1.5 in PKR, in the shape of pay order/demand draft/call deposit in the name of PITC Wapda house Lahore.....	It is requested to amend these clauses in line with performance clause against which bank guarantee has been required.	N/A
2	-	4.1(1)	Supply of equipment: Within one month (in PITC stores as per address mentioned in purchase order) from date of issuance of purchase order: however, in case of importable equipment to be shipped from abroad, delivery period can, however be allowed up to 45 days.	Extension in delivery period	The bidder will submit prototyping request within 15 days from the award of Letter of Acceptance; however, supply of meters must be completed within 30 days from the date of issuance of prototype certificate.
3	-	5.1	Liquidated Damages upon late delivery of supplies	Deduction of LD 1% is abnormal may be revised as 2% per month	NA
4	-	-	UDIL Certifications	What will be the cost of UDIL certification?	In this tender UDIL certification for participating bidders is free of cost.
5	-	A-1	Under the AMR meters description (A-1) Page 22 Accuracy Class of 0.5S has been required whereas specifications no. DDS-50:2007 has been referred. Please mention the reference of IEC 62053-22 and IEC 6253-23 (for accuracy test) in addition to the requirements mentioned in DDS-50:2007	The accuracy class 0.5s test is required in light of Letter issued by CE(D&S) NTDCL, Lahore No. 3692/CED&S/2184 dated 22-08-2013